

Lead Sample Results**Peru Central School District****Elementary (PreK-5)****Date Sampled: March 22, 2024. Laboratory results received: April 16th, 2024****Action Level for results: 5 ppb (parts per billion)****5 ppb = 0.005 mg/L (milligram per liter)****All Laboratory Analysis reported in mg/L.**

<u>Location</u>	<u>Laboratory Analysis</u>	<u>Corrective Action</u>
Sample #4: Intermediate Kitchen NE Sink	0.0063 mg/L	Signage Posted indicating "Hand-washing only. Do not drink".
Sample #15: Student Services Sink	0.0091 mg/L	Signage Posted indicating "Hand-washing only. Do not drink".



Laboratory Report

Champlain Valley Edu Services	200674
PO Box 455	
1443 Military Turnpike	
Plattsburgh, NY 12901	
Atten: Angela Jennette	

PROJECT: Lead in School Taps, Peru CSD
WORK ORDER: **2403-08018**
DATE RECEIVED: March 22, 2024
DATE REPORTED: April 15, 2024
SAMPLER: LeFevre

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, Peru CSD

WORK ORDER: **2403-08018**
DATE RECEIVED: 3/22/24

001	Site: Control Bottle			Stagnant:	8.55 Hrs	Date Sampled:	3/22/24	Time:	3:03
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A		
002	Site: Intermediate Kitchen West Sink			Stagnant:	8.57 Hrs	Date Sampled:	3/22/24	Time:	3:04
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0023	mg/L	EPA 200.8	4/9/24	W RSB	A		
003	Site: Intermediate Kitchen Kettle			Stagnant:	8.57 Hrs	Date Sampled:	3/22/24	Time:	3:04
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0027	mg/L	EPA 200.8	4/9/24	W RSB	A		
004	Site: Intermediate Kitchen NE Sink			Stagnant:	8.57 Hrs	Date Sampled:	3/22/24	Time:	3:04
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0063	mg/L	EPA 200.8	4/9/24	W RSB	A		
005	Site: Intermediate Kitchen SE Sink			Stagnant:	8.57 Hrs	Date Sampled:	3/22/24	Time:	3:04
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0040	mg/L	EPA 200.8	4/9/24	W RSB	A		
006	Site: Intermediate Nurse South Sink			Stagnant:	8.65 Hrs	Date Sampled:	3/22/24	Time:	3:09
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0023	mg/L	EPA 200.8	4/9/24	W RSB	A		
007	Site: Intermediate Nurse North Sink			Stagnant:	8.65 Hrs	Date Sampled:	3/22/24	Time:	3:09
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0020	mg/L	EPA 200.8	4/9/24	W RSB	A		
008	Site: Intermediate Bubbler 1stFl South			Stagnant:	8.67 Hrs	Date Sampled:	3/22/24	Time:	3:10
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A		
009	Site: Intermediate Bubbler 1stFl North			Stagnant:	8.67 Hrs	Date Sampled:	3/22/24	Time:	3:10
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A		
010	Site: Intermediate BottleFill 1stFl N			Stagnant:	8.67 Hrs	Date Sampled:	3/22/24	Time:	3:10
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, Peru CSD

WORK ORDER: 2403-08018
 DATE RECEIVED: 3/22/24

Lead, Total < 0.0010 mg/L EPA 200.8 4/9/24 W RSB A

011 Site: Intermediate Bubbler 2ndFl North Stagnant: 8.68 Hrs Date Sampled: 3/22/24 Time: 3:11

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A	

012 Site: Intermediate BottleFill 2ndFl N Stagnant: 8.68 Hrs Date Sampled: 3/22/24 Time: 3:11

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A	

013 Site: Elem Bubbler Student Services Stagnant: 8.75 Hrs Date Sampled: 3/22/24 Time: 3:15

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A	

014 Site: Elem BottleFill Student Services Stagnant: 8.75 Hrs Date Sampled: 3/22/24 Time: 3:15

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A	

015 Site: Student Services Sink Stagnant: 8.78 Hrs Date Sampled: 3/22/24 Time: 3:17

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0091	mg/L	EPA 200.8	4/9/24	W RSB	A	

016 Site: 12:1:3:1 East Sink Stagnant: 8.80 Hrs Date Sampled: 3/22/24 Time: 3:18

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0021	mg/L	EPA 200.8	4/9/24	W RSB	A	

017 Site: 12:1:3:1 West Sink Stagnant: 8.82 Hrs Date Sampled: 3/22/24 Time: 3:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0026	mg/L	EPA 200.8	4/9/24	W RSB	A	

018 Site: Elem. Bubbler Library Stagnant: 8.83 Hrs Date Sampled: 3/22/24 Time: 3:20

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A	

019 Site: Elem. BottleFill Library Stagnant: 8.83 Hrs Date Sampled: 3/22/24 Time: 3:20

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, Peru CSD

WORK ORDER: 2403-08018
DATE RECEIVED: 3/22/24

020	Site: Elem. Kitchen Kettle			Stagnant:	8.85 Hrs	Date Sampled:	3/22/24	Time:	3:21
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0011	mg/L	EPA 200.8	4/9/24	W RSB	A		
021	Site: Elem. Kitchen SE Prep Sink			Stagnant:	8.87 Hrs	Date Sampled:	3/22/24	Time:	3:22
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A		
022	Site: Elem. Kitchen Main Wash Sink			Stagnant:	8.87 Hrs	Date Sampled:	3/22/24	Time:	3:22
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0012	mg/L	EPA 200.8	4/9/24	W RSB	A		
023	Site: Elem. Kitchen NW Prep Sink			Stagnant:	8.87 Hrs	Date Sampled:	3/22/24	Time:	3:22
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/9/24	W RSB	A		
024	Site: Elem Staff Break Room Sink			Stagnant:	8.88 Hrs	Date Sampled:	3/22/24	Time:	3:23
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0012	mg/L	EPA 200.8	4/9/24	W RSB	A		
025	Site: Elem. Nurse West Sink			Stagnant:	8.92 Hrs	Date Sampled:	3/22/24	Time:	3:25
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/12/24	W RSB	A		
026	Site: Elem. Nurse Ice Machine			Stagnant:	8.93 Hrs	Date Sampled:	3/22/24	Time:	3:26
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/12/24	W RSB	A		
027	Site: Elem. Nurse East Sink			Stagnant:	8.97 Hrs	Date Sampled:	3/22/24	Time:	3:28
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.0024	mg/L	EPA 200.8	4/12/24	W RSB	A		
028	Site: Elem. Main Office Sink			Stagnant:	8.98 Hrs	Date Sampled:	3/22/24	Time:	3:29
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.0010	mg/L	EPA 200.8	4/12/24	W RSB	A		
029	Site: Elem. Bubbler by Ramp			Stagnant:	9.07 Hrs	Date Sampled:	3/22/24	Time:	3:34
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	

Laboratory Report

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	2403-08018
PROJECT:	Lead in School Taps, Peru CSD	DATE RECEIVED:	3/22/24
Lead, Total	< 0.0010	mg/L	EPA 200.8
			4/12/24
			W RSB
			A

030	Site: Elem. Bottle Fill by Ramp	Stagnant:	9.07 Hrs	Date Sampled:	3/22/24	Time:	3:34
-----	---------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/12/24	W RSB	A	

031	Site: Elem. Bubbler Gym	Stagnant:	9.08 Hrs	Date Sampled:	3/22/24	Time:	3:35
-----	-------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/12/24	W RSB	A	

032	Site: Elem. Bottle Fill Gym	Stagnant:	9.08 Hrs	Date Sampled:	3/22/24	Time:	3:35
-----	-----------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	4/12/24	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Education Services

Account #: *211274*

SAMPLE SUPPLY INFORMATION

Email Address: mlefevre@perucsd.org

PWS # Peru Water District

Contact Person: **Matt LeFevre**

Project Name **BOCES**

Collection Address: **116 Pleasant Street**

Phone: 518-643-6050

3T - Lead in Schools

Elementary / Intermediate School

PO #

City: Peru State: NY Zip: 12972

Pag 1 of 7

Collector's Name: LeFevre

SAMPLE MATRIX CODES

DW=drinking water SW+Surface Water
WW=waste water SD=solid
MW=monitoring well SO=soil
HW=hazardous waste SL=sludge

Compliance? Yes
Initial Testing
or
Repeat Testing

Bottle Tyoe / Volume
M
a
t
r
i
x
P
r
e
s
e
r
v
a
t
i
o
n
F
i
r
s
t
D
r
a
w
(Y)
F
l
u
s
h
e
d
L
i
n
e
(Y)
T
o
t
a
l
L
e
a
d

Analysis Requested:

TURNAROUND TIME REQUESTED
Standard (2-4 weeks)

Sample ID / Collection Site	Date/Time	Bottle Tyoe / Volume	M a t r i x	P r e s e r v a t i o n	F i r s t D r a w (Y)	F l u s h e d L i n e (Y)	T o t a l L e a d	Water Last Used (Date / Time)	Lab Use Sample #
1. Control Bottle	3/22/2024 3:03am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	001
2. Intermediate Kicthen - West Sink	3/22/2024 3:04am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	002
3. Intermediate Kicthen - Kettle	3/22/2024 3:04am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	003
4. Intermediate Kitchen - NE Sink	3/22/2024 3:04am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	004
5. Intermediate Kitchen - SE Sink	3/22/2024 3:04am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	005
6. Intermediate Nurse - South Sink	3/22/2024 3:09am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	006
7. Intermediate Nurse - North Sink	3/22/2024 3:09am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	007
8. Intermediate Bubbler - 1st flr - South	3/22/2024 3:10am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	008
9. Intermediate Bubbler - 1st flr - North	3/22/2024 3:10am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	009
10. Intermediate Bottle Fill- 1st flr - North	3/22/2024 3:10am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	010
11. Intermediate Bubbler - 2nd flr - North	3/22/2024 3:11am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	011
12. Intermediate Bottle Fill- 2nd flr - North	3/22/2024 3:11am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm	012

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact? <i>yes</i>	<i>22mar24</i>	<i>1104</i>	<i>[Signature]</i>	<i>[Signature]</i>
Filled to proper volume? <i>yes</i>				
# of Containers <i>32</i>				

2403-08018



Champlain Valley Edu Services
Lead in School Taps, Peru CSD

* Samples preserved with NHO3 to pH < 2 after receipt at the lab. *25mar24*

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$ *✓*

or A/R

Terms are net 30 days with

Payment Method Cash Check MC/Visa Money Order Check, MO, Receipt #

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Education Services		Account #:	SAMPLE SUPPLY INFORMATION		
Email Address: <u>mlefevre@perucsd.org</u>		PWS # Peru Water District			
Contact Person: Matt LeFevre		Project Name BOCES		Collection Address: 116 Pleasant Street	
Phone: 518-643-6050		3T - Lead in Schools		Elementary / Intermediate School	
PO #		City: Peru			State: NY Zip: 12972
		Pag 1 of 7		Collector's Name: LeFevre	

SAMPLE MATRIX CODES		Compliance? Yes Initial Testing or Repeat Testing		Bottle Type / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water									Water Last Used (Date / Time)		
WW=waste water	SD=solid											
MW=monitoring well	SO=soil											
HW=hazardous waste	SL=sludge											
TURNAROUND TIME REQUESTED												
Standard (2-4 weeks)												
Sample ID / Collection Site		Date/Time										
13. Elem. Bubbler (Student Services)		3/22/2024	3:15am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		013
14. Elem. Bottle Fill (Student Services)		3/22/2024	3:15am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		014
15. Student Services Sink		3/22/2024	3:17am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		015
16. 12:1:3:1 East Sink		3/22/2024	3:18am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		016
17. 12:1:3:1 West Sink		3/22/2024	3:19am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		017
18. Elem. Bubbler (Library)		3/22/2024	3:20am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		018
19. Elem. Bottle Fill (Library)		3/22/2024	3:20am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		019
20. Elem. Kitchen - Kettle		3/22/2024	3:21am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		020
21. Elem. Kitchen - SE Prep Sink		3/22/2024	3:22am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		021
22. Elem. Kitchen - Main Wash Sink		3/22/2024	3:22am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		022
23. Elem. Kitchen - NW Prep Sink		3/22/2024	3:22am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		023
24. Elem Staff Break Room Sink		3/22/2024	3:23am	250mL, P	DW	*	Y	N	X	March 21 around 6:30pm		024

SAMPLE RECEIPT (Lab Use Only)		Date	Time	Sample Relinquished By (SIGN HERE)			Samples Received By	
Samples Intact?								
Filled to proper volume?								
# of Containers								

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY		Terms are net 30 days with an open, up to date account					
Analysis Fee \$ _____	or A/R	Payment Method	<input type="checkbox"/> Cash	<input type="checkbox"/> Check	<input type="checkbox"/> MC/Visa	<input type="checkbox"/> Money Order	Check, MO, Receipt # _____

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Education Services		Account #:	SAMPLE SUPPLY INFORMATION	
Email Address:	mlefevre@perucsd.org		PWS #	Peru Water District
Contact Person:	Matt LeFevre	Project Name	BOCES	
Phone: 518-643-6050	3T - Lead in Schools		Collection Address:	116 Pleasant Street
PO #			City: Peru	State: NY Zip: 12972
		Pag 1 of 7	Collector's Name: LeFevre	

SAMPLE MATRIX CODES		Compliance? Yes Initial Testing or Repeat Testing	Bottle Type / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water								Water Last Used (Date / Time)		
WW=waste water	SD=solid										
MW=monitoring well	SO=soil										
HW=hazardous waste	SL=sludge										
TURNAROUND TIME REQUESTED											
Standard (2-4 weeks)											
Sample ID / Collection Site	Date/Time										
25. Elem. Nurse - West Sink	3/22/2024 3:25am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	025
26. Elem. Nurse - Ice Machine	3/22/2024 3:26am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	026
27. Elem. Nurse - East Sink	3/22/2024 3:28am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	027
28. Elem. Main Office Sink	3/22/2024 3:29am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	028
29. Elem. Bubbler - by Ramp	3/22/2024 3:34am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	029
30. Elem. Bottle Fill - by Ramp	3/22/2024 3:34am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	030
31. Elem. Bubbler - Gym	3/22/2024 3:35am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	031
32. Elem. Bottle Fill - Gym	3/22/2024 3:35am		250mL, P	DW	*	Y	N	X		March 21 around 6:30pm	032
	3/22/2024		250mL, P	DW	*	Y	N	X			
	3/22/2024		250mL, P	DW	*	Y	N	X			
	3/22/2024		250mL, P	DW	*	Y	N	X			
	3/22/2024		250mL, P	DW	*	Y	N	X			

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact?				
Filled to proper volume?				
# of Containers				

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$ _____ or A/R

Terms are net 30 days with an open, up to date account

Payment Method Cash Check MC/Visa Money Order

Check, MO, Receipt # _____