

**Lead Sample Results****Peru Central School District****High School - Middle School****Date Sampled: April 11, 2024. Laboratory results received: May 6th, 2024****Action Level for results: 5 ppb (parts per billion)****5 ppb = 0.005 mg/L (milligram per liter)****All Laboratory Analysis reported in mg/L.**

| <u>Location</u>                           | <u>Laboratory Analysis</u> | <u>Corrective Action</u>  |
|---|----------------------------|---|
| Sample #001: HS Kitchen NW Sink           | 0.0233 mg/L                | Signage Posted indicating "Hand-washing only. Do not drink". Faucet to be replaced, retest upon replacement.  |
| Sample #002: HS Kitchen West Kettle       | 0.0069 mg/L                | Signage Posted indicating "Hand-washing only. Do not drink". Plumbing lines and fittings to kettle will be replaced, retest upon replacment.  |
| Sample #003: HS Kitchen NE Sink-Left Bay  | 0.0066 mg/L                | Signage Posted indicating "Hand-washing only. Do not drink". Faucet to be replaced, retest upon replacement.  |
| Sample #005: HS Kitchen NE Sink-Right Bay | 0.0096 mg/L                | Signage Posted indicating "Hand-washing only. Do not drink". Faucet to be replaced, retest upon replacement.  |
| Sample #006: HS Kitchen East Kettle       | 0.0322 mg/L                | Signage Posted indicating "Hand-washing only. Do not drink". Plumbing lines and fittings to kettle will be replaced, retest upon replacment.  |
| Sample #007: Tilt Griddle Table           | 0.123 mg/L                 | Signage Posted indicating "Hand-washing only. Do not drink". Plumbing lines and fittings to appliance will be replaced. Investiagting replacement of faucet on appliance too, retest upon replacment. |
| Sample #038: MS Kitchen Prep Sink         | 0.0053 mg/L                | Signage Posted indicating "Hand-washing only. Do not drink". Faucet to be replaced, retest upon replacement.  |



Laboratory Report

Champlain Valley Edu Services      200674  
PO Box 455  
1443 Military Turnpike  
Plattsburgh, NY 12901  
Atten: Angela Jennette

PROJECT:    Lead in School Taps Peru MS/HS  
WORK ORDER:    **2404-10020**  
DATE RECEIVED:    April 11, 2024  
DATE REPORTED:    May 03, 2024  
SAMPLER:    LeFevre

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain  
Laboratory Director Plattsburgh, NY

### Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps Peru MS/HS

WORK ORDER: **2404-10020**  
DATE RECEIVED: 4/11/24

|                  |                                     |              |               |                      |                 |              |              |
|------------------|-------------------------------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| 001              | Site: HS Kitchen NW Sink            | Stagnant:    | 8.07 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:04         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0233                              | mg/L         | EPA 200.8     | 5/1/24               | W RSB           | A            |              |
| 002              | Site: HS Kitchen West Kettle        | Stagnant:    | 8.07 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:04         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0069                              | mg/L         | EPA 200.8     | 5/1/24               | W RSB           | A            |              |
| 003              | Site: HS Kitchen NE Sink-Left Bay   | Stagnant:    | 8.07 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:04         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0066                              | mg/L         | EPA 200.8     | 5/1/24               | W RSB           | A            |              |
| 004              | Site: HS Kitchen NE Sink-Middle Bay | Stagnant:    | 8.08 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:05         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0046                              | mg/L         | EPA 200.8     | 5/1/24               | W RSB           | A            |              |
| 005              | Site: HS Kitchen NE Sink-Right Bay  | Stagnant:    | 8.08 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:05         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0096                              | mg/L         | EPA 200.8     | 5/1/24               | W RSB           | A            |              |
| 006              | Site: HS Kitchen East Kettle        | Stagnant:    | 8.08 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:05         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0322                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |
| 007              | Site: Tilt Griddle Table            | Stagnant:    | 8.12 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:07         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.123                               | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |
| 008              | Site: HS Kitchen - SE Sink          | Stagnant:    | 8.13 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:08         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0014                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |
| 009              | Site: HS Kitchen Middle Prep Sink   | Stagnant:    | 8.13 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:08         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | 0.0024                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |
| 010              | Site: HS Cafeteria - Bubbler        | Stagnant:    | 8.15 Hrs      | Date Sampled:        | 4/11/24         | Time:        | 3:09         |
| <u>Parameter</u> | <u>Result</u>                       | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |

### Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps Peru MS/HS

WORK ORDER: **2404-10020**  
DATE RECEIVED: 4/11/24

Lead, Total < 0.0010 mg/L EPA 200.8 5/2/24 W RSB A

011 Site: HS Cafeteria - Bottle Fill Stagnant: 8.15 Hrs Date Sampled: 4/11/24 Time: 3:09

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

012 Site: D.O. Office Kitchen Sink Stagnant: 8.17 Hrs Date Sampled: 4/11/24 Time: 3:10

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

013 Site: HS Staff Break Room Kitchen Sink Stagnant: 8.20 Hrs Date Sampled: 4/11/24 Time: 3:12

| Parameter   | Result | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|--------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | 0.0040 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

014 Site: HS Gym/Aud. Bottle Fill Station Stagnant: 8.22 Hrs Date Sampled: 4/11/24 Time: 3:13

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

015 Site: HS Concession Stand Sink Stagnant: 8.25 Hrs Date Sampled: 4/11/24 Time: 3:15

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

016 Site: HS Fitness Room - Bubblers Stagnant: 8.27 Hrs Date Sampled: 4/11/24 Time: 3:16

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

017 Site: HS Fitness Room - Bottle Fill Stagnant: 8.27 Hrs Date Sampled: 4/11/24 Time: 3:16

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

018 Site: Wrestling Room - Bubblers Stagnant: 8.30 Hrs Date Sampled: 4/11/24 Time: 3:18

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

019 Site: Wrestling Room - Bottle Fill Stagnant: 8.30 Hrs Date Sampled: 4/11/24 Time: 3:18

| Parameter   | Result   | Units | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
|-------------|----------|-------|-----------|---------------|----------|-------|-------|
| Lead, Total | < 0.0010 | mg/L  | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

## Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps Peru MS/HS

WORK ORDER: 2404-10020  
DATE RECEIVED: 4/11/24

|                  |                                       |              |               |                      |                 |               |              |       |      |
|------------------|---------------------------------------|--------------|---------------|----------------------|-----------------|---------------|--------------|-------|------|
| 020              | Site: MS Gym Bubbler - North          |              |               | Stagnant:            | 8.33 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:20 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 021              | Site: MS Gym Bubbler - South          |              |               | Stagnant:            | 8.33 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:20 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 022              | Site: MS Gym Bubbler - Bottle Fill    |              |               | Stagnant:            | 8.33 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:20 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 023              | Site: MS Training Room Sink           |              |               | Stagnant:            | 8.35 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:21 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 024              | Site: HS Boys Locker Room-Bubbler     |              |               | Stagnant:            | 8.43 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:26 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 025              | Site: HS Boys Locker Room-Bottle Fill |              |               | Stagnant:            | 7.93 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:26 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 026              | Site: HS Lodge Bubbler - North        |              |               | Stagnant:            | 7.95 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:27 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 027              | Site: HS Lodge Bubbler - South        |              |               | Stagnant:            | 7.97 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:28 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 028              | Site: HS Lodge Bottle Fill            |              |               | Stagnant:            | 7.97 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:28 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |
| Lead, Total      | < 0.0010                              | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A             |              |       |      |
| 029              | Site: HS Office Kitchen Sink          |              |               | Stagnant:            | 8.05 Hrs        | Date Sampled: | 4/11/24      | Time: | 3:33 |
| <u>Parameter</u> | <u>Result</u>                         | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u>  | <u>Qual.</u> |       |      |

### Laboratory Report

|   |                               |
|---|-------------------------------|
| CLIENT: Champlain Valley Edu Services   | WORK ORDER: <b>2404-10020</b> |
| PROJECT: Lead in School Taps Peru MS/HS | DATE RECEIVED: 4/11/24        |
| Lead, Total 0.0035 mg/L EPA 200.8       | 5/2/24 W RSB A                |

|                                  |           |          |               |         |            |
|----------------------------------|-----------|----------|---------------|---------|------------|
| 030 Site: HS Guidance - Bubblers | Stagnant: | 8.07 Hrs | Date Sampled: | 4/11/24 | Time: 3:34 |
|----------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | < 0.0010      | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                                     |           |          |               |         |            |
|-------------------------------------|-----------|----------|---------------|---------|------------|
| 031 Site: HS Guidance - Bottle Fill | Stagnant: | 8.07 Hrs | Date Sampled: | 4/11/24 | Time: 3:34 |
|-------------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | < 0.0010      | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                                  |           |          |               |         |            |
|----------------------------------|-----------|----------|---------------|---------|------------|
| 032 Site: MS Nurse Bubblers - NW | Stagnant: | 8.10 Hrs | Date Sampled: | 4/11/24 | Time: 3:36 |
|----------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | < 0.0010      | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                                  |           |          |               |         |            |
|----------------------------------|-----------|----------|---------------|---------|------------|
| 033 Site: MS Nurse Bubblers - SE | Stagnant: | 8.12 Hrs | Date Sampled: | 4/11/24 | Time: 3:37 |
|----------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | < 0.0010      | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                                  |           |          |               |         |            |
|----------------------------------|-----------|----------|---------------|---------|------------|
| 034 Site: MS Nurse - Bottle Fill | Stagnant: | 7.95 Hrs | Date Sampled: | 4/11/24 | Time: 3:27 |
|----------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | < 0.0010      | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                                  |           |          |               |         |            |
|----------------------------------|-----------|----------|---------------|---------|------------|
| 035 Site: MS Nurse - Office Sink | Stagnant: | 7.95 Hrs | Date Sampled: | 4/11/24 | Time: 3:27 |
|----------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | 0.0013        | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                              |           |          |               |         |            |
|------------------------------|-----------|----------|---------------|---------|------------|
| 036 Site: MS Conference Sink | Stagnant: | 7.97 Hrs | Date Sampled: | 4/11/24 | Time: 3:28 |
|------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | 0.0036        | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                              |           |          |               |         |            |
|------------------------------|-----------|----------|---------------|---------|------------|
| 037 Site: MS Break Room Sink | Stagnant: | 7.65 Hrs | Date Sampled: | 4/11/24 | Time: 3:39 |
|------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | 0.0018        | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

|                                |           |          |               |         |            |
|--------------------------------|-----------|----------|---------------|---------|------------|
| 038 Site: MS Kitchen Prep Sink | Stagnant: | 7.67 Hrs | Date Sampled: | 4/11/24 | Time: 3:40 |
|--------------------------------|-----------|----------|---------------|---------|------------|

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>Method</u> | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
|------------------|---------------|--------------|---------------|----------------------|-----------------|--------------|--------------|
| Lead, Total      | 0.0053        | mg/L         | EPA 200.8     | 5/2/24               | W RSB           | A            |              |

## Laboratory Report

CLIENT: Champlain Valley Edu Services  
 PROJECT: Lead in School Taps Peru MS/HS

WORK ORDER: 2404-10020  
 DATE RECEIVED: 4/11/24

039 Site: M11 Bubblers-East NOT USED Stagnant: 24.00 Hrs Date Sampled: 4/11/24 Time: 0:00

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

No analysis

040 Site: M11 Bubblers - West Stagnant: 7.70 Hrs Date Sampled: 4/11/24 Time: 3:42

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |        |      |           |        |       |   |  |
|-------------|--------|------|-----------|--------|-------|---|--|
| Lead, Total | 0.0017 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|--------|------|-----------|--------|-------|---|--|

041 Site: M11 Bottle Fill Stagnant: 7.70 Hrs Date Sampled: 4/11/24 Time: 3:42

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |          |      |           |        |       |   |  |
|-------------|----------|------|-----------|--------|-------|---|--|
| Lead, Total | < 0.0010 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|----------|------|-----------|--------|-------|---|--|

042 Site: M26 Bubblers-East NOT USED Stagnant: 24.00 Hrs Date Sampled: 4/11/24 Time: 0:00

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

No analysis

043 Site: M26 Bubblers - West Stagnant: 7.78 Hrs Date Sampled: 4/11/24 Time: 3:47

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |          |      |           |        |       |   |  |
|-------------|----------|------|-----------|--------|-------|---|--|
| Lead, Total | < 0.0010 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|----------|------|-----------|--------|-------|---|--|

044 Site: M26 Bottle Fill Stagnant: 7.78 Hrs Date Sampled: 4/11/24 Time: 3:47

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |          |      |           |        |       |   |  |
|-------------|----------|------|-----------|--------|-------|---|--|
| Lead, Total | < 0.0010 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|----------|------|-----------|--------|-------|---|--|

045 Site: M20 - West Sink Stagnant: 7.82 Hrs Date Sampled: 4/11/24 Time: 3:49

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |        |      |           |        |       |   |  |
|-------------|--------|------|-----------|--------|-------|---|--|
| Lead, Total | 0.0019 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|--------|------|-----------|--------|-------|---|--|

046 Site: M20 - Middle Sink Stagnant: 7.82 Hrs Date Sampled: 4/11/24 Time: 3:49

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |        |      |           |        |       |   |  |
|-------------|--------|------|-----------|--------|-------|---|--|
| Lead, Total | 0.0016 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|--------|------|-----------|--------|-------|---|--|

047 Site: M20 - East Sink Stagnant: 7.82 Hrs Date Sampled: 4/11/24 Time: 3:49

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

|             |        |      |           |        |       |   |  |
|-------------|--------|------|-----------|--------|-------|---|--|
| Lead, Total | 0.0018 | mg/L | EPA 200.8 | 5/2/24 | W RSB | A |  |
|-------------|--------|------|-----------|--------|-------|---|--|

048 Site: H209 Bubblers-West NOT USED Stagnant: 24.00 Hrs Date Sampled: 4/11/24 Time: 0:00

| Parameter | Result | Units | Method | Analysis Date | Lab/Tech | NELAC | Qual. |
|-----------|--------|-------|--------|---------------|----------|-------|-------|
|-----------|--------|-------|--------|---------------|----------|-------|-------|

### Laboratory Report

CLIENT: Champlain Valley Edu Services  
 PROJECT: Lead in School Taps Peru MS/HS  
 No analysis

WORK ORDER: **2404-10020**  
 DATE RECEIVED: 4/11/24

| 049         | Site: H209 Bubblers - West | Stagnant: | 7.33 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:50  |
|-------------|----------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                     | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                   | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 050         | Site: H209 Bottle Fill | Stagnant: | 7.33 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:50  |
|-------------|------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                 | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010               | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 051         | Site: M36 Bubblers - South | Stagnant: | 7.35 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:51  |
|-------------|----------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                     | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                   | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 052         | Site: M36 Bubblers - North | Stagnant: | 7.35 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:51  |
|-------------|----------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                     | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                   | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 053         | Site: M36 - Bottle Fill | Stagnant: | 7.35 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:51  |
|-------------|-------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                  | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 054         | Site: MS 2nd Flr Break Room Sink | Stagnant: | 7.42 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:55  |
|-------------|----------------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                           | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | 0.0027                           | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 055         | Site: HS Girls Lockerroom-West Bubblers | Stagnant: | 8.22 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:28  |
|-------------|---|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                                  | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                                | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 056         | Site: HS Girls Lockerroom-East Bubblers | Stagnant: | 8.22 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:28  |
|-------------|---|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                                  | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                                | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |

  

| 057         | Site: HS Girls Lockerroom-Bottle Fill | Stagnant: | 8.22 Hrs  | Date Sampled: | 4/11/24  | Time: | 3:28  |
|-------------|---------------------------------------|-----------|-----------|---------------|----------|-------|-------|
| Parameter   | Result                                | Units     | Method    | Analysis Date | Lab/Tech | NELAC | Qual. |
| Lead, Total | < 0.0010                              | mg/L      | EPA 200.8 | 5/2/24        | W RSB    | A     |       |



**Laboratory Report**

CLIENT: Champlain Valley Edu Services  
 PROJECT: Lead in School Taps Peru MS/HS

WORK ORDER: **2404-10020**  
 DATE RECEIVED: 4/11/24

|                  |                      |                     |                       |                      |                 |              |              |
|------------------|----------------------|---------------------|-----------------------|----------------------|-----------------|--------------|--------------|
| 058              | Site: HS Ice Machine | Stagnant: 27.37 Hrs | Date Sampled: 4/11/24 | Time: 3:22           |                 |              |              |
| <u>Parameter</u> | <u>Result</u>        | <u>Units</u>        | <u>Method</u>         | <u>Analysis Date</u> | <u>Lab/Tech</u> | <u>NELAC</u> | <u>Qual.</u> |
| Lead, Total      | < 0.0010             | mg/L                | EPA 200.8             | 5/2/24               | W RSB           | A            |              |

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services

Account #: 200674

**SAMPLE SUPPLY INFORMATION**

Email Address: mlefevre@perucsd.org

PWS # Peru Water District

Contact Person: Matt LeFevre

Project Name BOCES

Collection Address: 17 School Street

Phone: 518-643-6050

3T - Lead in Schools

High School - Middle School

PO #

City: Peru State: NY Zip: 12972

Pag 1 of 7

Collector's Name: LeFevre

**SAMPLE MATRIX CODES**

|                    |                  |  |
|--------------------|------------------|--|
| DW=drinking water  | SW=Surface Water | Compliance? Yes<br>Initial Testing<br>or<br>Repeat Testing |
| WW=waste water     | SD=solid         |  |
| MW=monitoring well | SO=soil          |  |
| HW=hazardous waste | SL=sludge        |  |

**TURNAROUND TIME REQUESTED**

Standard (2-4 weeks)

| Sample ID / Collection Site        | Date/Time |        | Bottle Type / Volume | Matrix | Preservation | First Draw (Y) | Flushed Line (Y) | Total Lead | Analysis Requested:           |                 | Lab Use Sample # |
|------------------------------------|-----------|--------|----------------------|--------|--------------|----------------|------------------|------------|-------------------------------|-----------------|------------------|
|                                    |           |        |                      |        |              |                |                  |            | Water Last Used (Date / Time) |                 |                  |
| 1. HS kitchen NW sink              | 4/11/2024 | 3:04am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 001              |
| 2. HS kitchen west kettle          | 4/11/2024 | 3:04am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 002              |
| 3. HS kitchen NE sink - left bay   | 4/11/2024 | 3:04am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 003              |
| 4. HS kitchen NE sink - middle bay | 4/11/2024 | 3:05am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 004              |
| 5. HS kitchen NE sink - right bay  | 4/11/2024 | 3:05am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 005              |
| 6. HS kitchen east kettle          | 4/11/2024 | 3:05am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 006              |
| 7. Tilt Griddle Table              | 4/11/2024 | 3:07am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 007              |
| 8. HS kitchen - SE sink            | 4/11/2024 | 3:08am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 008              |
| 9. HS kitchen middle prep sink     | 4/11/2024 | 3:08am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 009              |
| 10. HS Cafeteria - Bubbler         | 4/11/2024 | 3:09am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 010              |
| 11. HS Cafeteria - Bottle Fill     | 4/11/2024 | 3:09am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 011              |
| 12. D.O. Office Kitchen Sink       | 4/11/2024 | 3:10am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 012              |

| SAMPLE RECEIPT (Lab Use Only) |     | Date      | Time | Sample Relinquished By (SIGN HERE) | Samples Received By |
|-------------------------------|-----|-----------|------|------------------------------------|---------------------|
| Samples Intact?               | YES | 11 Apr 24 | 0945 | <i>[Signature]</i>                 | <i>[Signature]</i>  |
| Filled to proper volume?      | YES |           |      |                                    |                     |
| # of Containers               | 54  |           |      |                                    |                     |

2404-10020



Champlain Valley Edu Services  
Lead in School Taps Peru MS/HS

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab. 11 Apr 24

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

**OFFICE USE ONLY**

Analysis Fee \$ \_\_\_\_\_ or A/R

Terms are net 30 days with an open, up to date account

Payment Method  Cash  Check  MC/Visa  Money Order

Check, MO, Receipt # \_\_\_\_\_

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services

Account #:

**SAMPLE SUPPLY INFORMATION**

Email Address: mlefevre@perucsd.org

PWS # Peru Water District

Contact Person: Matt LeFevre

Project Name BOCES

Collection Address: 17 School Street

Phone: 518-643-6050

3T - Lead in Schools

High School - Middle School

PO #

City: Peru State: NY Zip: 12972

Pag 1 of 7

Collector's Name: LeFevre

**SAMPLE MATRIX CODES**

DW=drinking water SW=Surface Water  
WW=waste water SD=solid  
MW=monitoring well SO=soil  
HW=hazardous waste SL=sludge

Compliance? Yes  
Initial Testing  
or  
Repeat Testing

**TURNAROUND TIME REQUESTED**

Standard (2-4 weeks)

| Sample ID / Collection Site           | Date/Time |        | Bottle Type / Volume | Matrix | Preservation | First Draw (Y) | Flushed Line (Y) | Total Lead | Analysis Requested:           |                 | Lab Use Sample # |
|---------------------------------------|-----------|--------|----------------------|--------|--------------|----------------|------------------|------------|-------------------------------|-----------------|------------------|
|                                       |           |        |                      |        |              |                |                  |            | Water Last Used (Date / Time) |                 |                  |
| 13. HS Staff Break Room Kitchen Sink  | 4/11/2024 | 3:12am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 001              |
| 14. HS Gym / Aud. Bottle fill station | 4/11/2024 | 3:13am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 002              |
| 15. HS concession stand sink          | 4/11/2024 | 3:15am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 003              |
| 16. HS Fitness Room - Bubblers        | 4/11/2024 | 3:16am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 004              |
| 17. HS Fitness Room - Bottle Fill     | 4/11/2024 | 3:16am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 005              |
| 18. Wrestling Room - Bubblers         | 4/11/2024 | 3:18am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 006              |
| 19. Wrestling Room - Bottle Fill      | 4/11/2024 | 3:18am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 007              |
| 20. MS Gym Bubblers - North           | 4/11/2024 | 3:20am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 008              |
| 21. MS Gym Bubblers - South           | 4/11/2024 | 3:20am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 009              |
| 22. MS Gym Bubblers - Bottle Fill     | 4/11/2024 | 3:20am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 010              |
| 23. MS Training Room Sink             | 4/11/2024 | 3:21am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 011              |
| 24. HS Boys Locker Room - Bubblers    | 4/11/2024 | 3:26am | 250mL, P             | DW     | *            | Y              | N                | X          |                               | April 10 7:00pm | 012              |

| SAMPLE RECEIPT (Lab Use Only) | Date | Time | Sample Relinquished By (SIGN HERE) | Samples Received By |
|-------------------------------|------|------|------------------------------------|---------------------|
| Samples Intact?               |      |      |                                    |                     |
| Filled to proper volume?      |      |      |                                    |                     |
| # of Containers               |      |      |                                    |                     |

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

**OFFICE USE ONLY**

Terms are net 30 days with an open, up to date account

Analysis Fee \$ \_\_\_\_\_ or A/R Payment Method  Cash  Check  MC/Visa  Money Order Check, MO, Receipt # \_\_\_\_\_

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services

Account #:

**SAMPLE SUPPLY INFORMATION**

Email Address: mlefevre@perucsd.org

PWS # Peru Water District

Contact Person: Matt LeFevre

Project Name BOCES

Collection Address: 17 School Street

Phone: 518-643-6050

3T - Lead in Schools

High School - Middle School

PO #

City: Peru

State: NY

Zip: 12972

Pag 1 of 7

Collector's Name: LeFevre

**SAMPLE MATRIX CODES**

DW=drinking water SW+Surface Water  
WW=waste water SD=solid  
MW=monitoring well SO=soil  
HW=hazardous waste SL=sludge

Compliance? Yes  
Initial Testing  
or  
Repeat Testing

**TURNAROUND TIME REQUESTED**

Standard (2-4 weeks)

| Sample ID / Collection Site           | Date/Time        | Bottle Type / Volume | Matrix | Preservation | First Draw (Y) | Flushed Line (Y) | Total Lead | Analysis Requested:           |  | Lab Use Sample # |
|---------------------------------------|------------------|----------------------|--------|--------------|----------------|------------------|------------|-------------------------------|--|------------------|
|                                       |                  |                      |        |              |                |                  |            | Water Last Used (Date / Time) |  |                  |
| 25. HS Boys Locker Room - Bottle Fill | 4/11/2024 3:26am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 001              |
| 26. HS Lodge Bubbler - North          | 4/11/2024 3:27am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 002              |
| 27. HS Lodge Bubbler - South          | 4/11/2024 3:28am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 003              |
| 28. HS Lodge Bottle Fill              | 4/11/2024 3:28am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 004              |
| 29. HS Office Kitchen Sink            | 4/11/2024 3:33am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 005              |
| 30. HS Guidance - Bubbler             | 4/11/2024 3:34am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 006              |
| 31. HS Guidance - Bottle Fill         | 4/11/2024 3:34am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 007              |
| 32. MS Nurse Bubbler - NW             | 4/11/2024 3:36am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 008              |
| 33. MS Nurse Bubbler - SE             | 4/11/2024 3:37am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 009              |
| 34. MS Nurse - Bottle Fill            | 4/11/2024 3:27am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 010              |
| 35. MS Nurse - Office Sink            | 4/11/2024 3:27am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 011              |
| 36. MS Conference Sink                | 4/11/2024 3:28am | 250mL, P             | DW     | *            | Y              | N                | X          | April 10 around 7:30pm        |  | 012              |

| SAMPLE RECEIPT (Lab Use Only) | Date | Time | Sample Relinquished By (SIGN HERE) | Samples Received By |
|-------------------------------|------|------|------------------------------------|---------------------|
| Samples Intact?               |      |      |                                    |                     |
| Filled to proper volume?      |      |      |                                    |                     |
| # of Containers               |      |      |                                    |                     |

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

**OFFICE USE ONLY**

Terms are net 30 days with an open, up to date account

Analysis Fee \$ \_\_\_\_\_ or A/R

Payment Method  Cash  Check  MC/Visa  Money Order

Check, MO, Receipt # \_\_\_\_\_

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services

Account #:

**SAMPLE SUPPLY INFORMATION**

Email Address: [miefevre@perucsd.org](mailto:miefevre@perucsd.org)

PWS # Peru Water District

Contact Person: Matt LeFevre

Project Name BOCES

Collection Address: 17 School Street

Phone: 518-643-6050

3T - Lead in Schools

High School - Middle School

PO #

City: Peru State: NY Zip: 12972

Pag 1 of 7

Collector's Name: LeFevre

**SAMPLE MATRIX CODES**

DW=drinking water SW=Surface Water  
WW=waste water SD=solid  
MW=monitoring well SO=soil  
HW=hazardous waste SL=sludge

Compliance? Yes  
Initial Testing  
or  
Repeat Testing

**TURNAROUND TIME REQUESTED**

Standard (2-4 weeks)

Sample ID / Collection Site

Date/Time

Bottle Type / Volume

Matrix

Preservation

First Draw (Y)

Flushed Line (Y)

Total Lead

**Analysis Requested:**

Water Last Used  
(Date / Time)

Lab Use

Sample #

37. MS Break Room Sink

4/11/2024 3:39am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

001

38. MS Kitchen Prep Sink

4/11/2024 3:40am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

002

39. M11 Bubbler - East Not used

4/11/2024 n/a

250mL, P

DW

\*

Y

N

X

n/a

003

40. M11 Bubbler - West

4/11/2024 3:42am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

004

41. M11 Bottle Fill

4/11/2024 3:42am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

005

42. M26 Bubbler - East Not Used

4/11/2024 n/a

250mL, P

DW

\*

Y

N

X

n/a

006

43. M26 Bubbler - West

4/11/2024 3:47am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

007

44. M26 Bottle Fill

4/11/2024 3:47am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

008

45. M20 - West Sink

4/11/2024 3:49am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

009

46. M20 - Middle Sink

4/11/2024 3:49am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

010

47. M20 - East Sink

4/11/2024 3:49am

250mL, P

DW

\*

Y

N

X

April 10 around 8:00pm

011

48. H200 Bubbler - West Not Used

4/11/2024 n/a

250mL, P

DW

\*

Y

N

X

n/a

012

**SAMPLE RECEIPT (Lab Use Only)**

Date

Time

Sample Relinquished By (SIGN HERE)

Samples Received By

Samples Intact?

Filled to proper volume?

# of Containers

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

**OFFICE USE ONLY**

Terms are net 30 days with an open, up to date account

Analysis Fee \$

or A/R

Payment Method

Cash

Check

MC/Visa

Money Order

Check, MO, Receipt #

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: Champlain Valley Education Services

Account #:

**SAMPLE SUPPLY INFORMATION**

Email Address: [mlefevre@perucsd.org](mailto:mlefevre@perucsd.org)

PWS # Peru Water District

Contact Person: Matt LeFevre

Project Name BOCES

Collection Address: 17 School Street

Phone: 518-643-6050

3T - Lead in Schools

High School - Middle School

PO #

City: Peru

State: NY

Zip: 12972

Pag 1 of 7

Collector's Name: LeFevre

**SAMPLE MATRIX CODES**

DW=drinking water SW+Surface Water  
WW=waste water SD=solid  
MW=monitoring well SO=soil  
HW=hazardous waste SL=sludge

Compliance? Yes  
Initial Testing  
or  
Repeat Testing

**TURNAROUND TIME REQUESTED**

Standard (2-4 weeks)

Sample ID / Collection Site

Date/Time

Bottle Type / Volume

Matrix

Preservation

First Draw (Y)

Flushed Line (Y)

Total Lead

**Analysis Requested:**

Water Last Used  
(Date / Time)

Lab Use

Sample #

49. H209 Bubbler - West

4/11/2024 3:50am

250mL, P

DW

\*

Y

N

X

April 10 around 8:30pm

001

50. H209 Bottle Fill

4/11/2024 3:50am

250mL, P

DW

\*

Y

N

X

April 10 around 8:30pm

002

51. M36 Bubbler - South

4/11/2024 3:51am

250mL, P

DW

\*

Y

N

X

April 10 around 8:30pm

003

52. M36 Bubbler - North

4/11/2024 3:51am

250mL, P

DW

\*

Y

N

X

April 10 around 8:30pm

004

53. M36 - Bottle Fill

4/11/2024 3:51am

250mL, P

DW

\*

Y

N

X

April 10 around 8:30pm

005

54. MS 2nd Fir Break Room Sink

4/11/2024 3:55am

250mL, P

DW

\*

Y

N

X

April 10 around 8:30pm

006

55. HS Girls Lockerroom - West Bubbler

4/11/2024 3:28am

250mL, P

DW

\*

Y

N

X

April 10 around 7:15pm

007

56. HS Girls Lockerroom - East Bubbler

4/11/2024 3:28am

250mL, P

DW

\*

Y

N

X

April 10 around 7:15pm

008

57. HS Girls Lockerroom - Bottle Fill

4/11/2024 3:28am

250mL, P

DW

\*

Y

N

X

April 10 around 7:15pm

009

58. HS Ice Machine

4/11/2024 3:22am

250mL, P

DW

\*

Y

N

X

n/a

010

250mL, P

DW

\*

Y

N

X

011

250mL, P

DW

\*

Y

N

X

012

**SAMPLE RECEIPT (Lab Use Only)**

Date

Time

Sample Relinquished By (SIGN HERE)

Samples Received By

Samples Intact?

Filled to proper volume?

# of Containers

\* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

**OFFICE USE ONLY**

Analysis Fee \$ \_\_\_\_\_ or A/R

Payment Method  Cash  Check  MC/Visa  Money Order

Check, MO, Receipt # \_\_\_\_\_

Terms are net 30 days with an open, up to date account